



**WEST NORRITON TOWNSHIP
SANITARY SEWER ENGINEER'S
MONTHLY REPORT
for the Board of Commissioners Meeting on
February 8, 2021**

Special Projects

1. PA Small Water and Sewer Grant Application – Forest Avenue PS Project has been awarded \$150,000 in grant funding from DCED on September 18, 2018. Bids have been received for the Project and awarded to A.J. Jurich, Inc. (General/Mechanical Contractor) in the amount of \$127,000 and Wise Electrical Contractors, LLC (Electrical Contractor) in the amount of \$121,100, including Alternate No. 1 per Recommendation Letter. Coordinating contract agreements and pre-construction meeting to commence work.
2. Sewage Facilities Program Grant Application – PA DEP approved Plan of Study and Task Activity Report on May 23, 2018. 537 Plan Update was awarded full grant amount of \$69,000 (50% match) for this project. Agreements are executed and plan preparation is underway.
3. Chapter 94 Wasteload Management Report – Preparation of report underway.
4. Rittenhouse Pump Station Force Main Analysis – Report issued to Commissioners for review.

Developments

1. Markley Farms (Phase I) Sanitary sewer installation and testing is completed. All tests passed. Sewer televising videos received reviewed. As-built plans were received and review issued 1/15/2020.
2. Markley Farms (Phase II) - Construction has installed all sanitary sewer items to be dedicated to the Township. Sewer mains and manholes have passed mandrel, air and vacuum tests. Sewer main has been televised. Sewer videos have been submitted and review issued.
3. Reserve at Stoney Creek – Revised sewer televising videos reviewed and review letter sent. Repairs were made and air testing passed. Developer submitted revised video inspection and repair found to be acceptable.
4. 2495 Gen. Armistead – Continued construction observation of sewer lateral connection.
5. 48 Potts Avenue – No work completed this month for sewer.
6. 60 W. Indian Lane – Reviewed sewer plans for existing single family home replacement.
7. 1807 Sterigere Street – Reviewed As-Built Plan. Review letter issued December 9, 2020
8. 2484 Stinson Lane – Reviewed sewer connection application and coordinate planning.

Meetings

1. Commissioners meeting on January 12, 2020.
2. Staff meeting on January 20, 2020.

Prepared by: Thomas J. Figaniak, P.E.
Prepared Date: February 4, 2021
File No.: 21-01081T